



**Ventura County Community College District**  
761 East Daily Drive, Camarillo, CA 93010  
Purchasing Department

TO: All Bidders April 16, 2019  
FROM: Janice Kisch, Purchasing Specialist  
SUBJECT: Bid 566, Districtwide Parking & Roadway Maintenance

**Bid 566, Districtwide Parking & Roadway Maintenance – Addendum 1**

This addendum is hereby made a part of the contract documents to the same extent as though it was originally included therein and takes precedence over the original documents.

**Note that the Bid Proposal Form requires acknowledgement of receipt of all addenda.**

It is the responsibility of the Bidder to verify that their Bid Proposal and all addenda has been received and delivered to the VCCCD Purchasing Department prior to the bid opening date and time. Verification of receipt can be obtained through the listed Purchasing Specialist.

---

**New Information:**

- 1) **The Due Date for this Bid has been extended. The New Date to Submit Bids will be Thursday, April 25 at 3:00 PM.**
- 2) **Deadline for questions will also be extended to 12:00 Noon this Friday, April 19.**
- 3) **Section 1: Maintenance Garage Area - Adjust vault cover to finish grade.**
- 4) **Section 5: Communications Parking Lot at Moorpark College has been removed from the Bid. The college will address this lot at a later time.**
- 5) **Section 6: AA Lot to include Remove and Replace repair of the pothole in E lot.**
- 6) **Add Alternates will be added to Sections 1 and 3 at Moorpark College, and Section 8 at Oxnard College. The alternates are listed below and will be noted on the Revised Schedule of Values form. Alternates may or may not be awarded with the Section. Do not include the cost of the alternate on the Base Bid form of the Section.**
- 7) **Section 9: West Parking Lot repairs will be combined with Section 10 - T Lot at Ventura College as one section of the bid. Section 10 is removed.**

## **General Information:**

- 1) Expect petromat to be found in asphalt concrete at all colleges – remove and dispose of offsite.
- 2) Contractor to memorialize pavement markings or monuments and restore.
- 3) Existing curb bollards (bumper stops) may be re-used if not damaged or cracked
- 4) Pressure-treated wood may be used in lieu of redwood for headers.
- 5) Moorpark and Ventura Colleges will accept clean subgrade and base materials in designated areas (At Moorpark College see “Stockpile Area” on plan, at Ventura College, the stockpile area is at the former pool location located on West campus Way, approximately 900 feet south of the West Parking Lot.)
- 6) Add Alternates will be included in the final revision of the Schedule of Values. Do not include the cost of the Alternate in the Base Bid of that Section.
- 7) Bid is scheduled for award on May 14. Work may start upon receiving all required documents and a Notice to Proceed letter from the District.

## **Summary of Add Alternates, (4):**

### **Moorpark College:**

#### **Section 2: Field House Road and Maintenance Entrance**

Add Alternate 2A: Maintenance Frontage Road north of Entrance

#### **Section 3: Entrance of H Lot and Parking Structure Road, ('Y' entry)**

Add Alternate 3A: Remove & Replace entire H Lot road west to gate

### **Oxnard College:**

#### **Section 8: Football Field Pathway**

Add Alternate 8A: Omit grinding and overlay of east fire access road along north side of track, but Seal Coat Track Entry and North Fire Road

Add Alternate 8B: Grind and Overlay (1.5”) 1,000 square feet of pavement center along North side of Gymnasium