

**SECTION 32 17 23
TACTILE WARNING STRIPS**

PART 1 GENERAL

1.01 SECTION INCLUDES

This section includes general requirements for the installation of the tactile warning strips, also referred to as truncated domes.

1.02 QUALITY ASSURANCE

Contractor must have experience in installing truncated domes.

1.03 SUBMITTALS

Submit Manufacturer's product data sheets.

1.04 PRODUCT HANDLING

Deliver materials to job site in unopened containers bearing Manufacturer's name and product description, and store in safe place until installation.

PART 2 PRODUCTS

2.01 TACTILE WARNING STRIPS / TRUNCATED DOMES

Truncated domes shall be replaceable cast-in-place detectable/tactile warning surface as manufactured by Access-Tile, or equal. Color shall be Federal Yellow. Tiles shall have a nylon composite, corrosive resistant anchor system with stainless-steel fasteners.

PART 3 EXECUTION

3.01 INSTALLATION

Set tiles in wet concrete surface and follow the manufacture's installation requirements. Tile surface width will vary as per plan. Install modules to make up the required width and the depth of three feet.

3.02 CODE COMPLIANCE

Only approved DSA-AC detectable warning products and directional surfaces shall be installed as provided by the California Code of Regulations (CCR), Title 24, Chapter 5, Articles 2,3, and 4. And 11B-705.

END OF SECTION 32 17 23