



Ventura County Community College District

PURCHASING DEPARTMENT

DATE: September 5, 2025
TO: All Bidders
FROM: Renée Knight, Purchasing Specialist
SUBJECT: Addendum #1– Bid #713, Oxnard College PE Building Painting Project

This addendum is hereby made part of the Contract Documents to the same extent as though it was originally included therein and takes precedence over the original documents. The outdated pages must be replaced with any updated and/or changed pages when submitting your bid. Acknowledge receipt of all addenda on the Bid Form.

The bid opening remains on **Monday, September 15, 2025**. Bids must be received no later than **3:00 p.m.** at 761 E Daily Drive, Suite 200, Camarillo, CA 93010. Properly mark the outside of the exterior envelope on your submitted bid with the Bid Number and Name according to the requirements stated in the bid packet directions.

If you choose not to participate in this particular bid, please sign the Bid Proposal stating “no bid” and email or fax it back to me at 805-652-7700.

It is the responsibility of the Bidder to verify that their proposal has been received by the VCCCD Purchasing Department prior to the opening date. Verification of receipt can be made through the listed Purchasing Specialist.

The following information is in answer to questions that were asked at the job walk and via email request. The deadline for questions is **3pm, Monday, September 8, 2025**.

1. When is the start date of the Project?

Answer: Project cannot start until Board Approved. Barring unforeseen delays, we estimate to bring the project to Board on Tuesday 13 October 2025, and if approved, PO will be issued by Friday 16 October 2025.

2. Are we painting the metal roofs?

Answer: Yes

3. Are we painting the metal louvers on the roof?

Answer: Yes

4. Are we painting the window and door frames?

Answer: Yes, Door frames and window frames, Excluding existing aluminum finishes

5. Are we painting interior of all exterior doors?

Answer: Yes



Ventura County Community College District

PURCHASING DEPARTMENT

6. Does the contract call for spot prime and full finish coat on the main walls of the building or do we apply a full coat of primer then 2 coats of finish?...the specs do not clearly specify...please clarify.

Answer: Full prime and minimum 2 coats of finish

End of Section