



# Ventura County Community College District

PURCHASING DEPARTMENT

---

DATE: July 2, 2019  
TO: All Bidders  
FROM: Jo Nell Miller, Purchasing Specialist  
SUBJECT: Addendum 1 – Bid 581 Ventura College Lock Hardware Project

*This addendum is hereby made part of the Contract Documents to the same extent as though it was originally included therein and takes precedence over the original documents. The outdated pages must be replaced with any updated and/or changed pages when submitting your bid. **Acknowledge receipt of all addenda on the Bid Form.***

The bid opening remains on **Thursday, July 11, 2019**. Bids must be received no later than **3:00 p.m.** at 761 E Daily Drive, Suite 200, Camarillo, CA 93010. Properly mark the outside of the exterior envelope on your submitted bid with the Bid Number and Name according to the requirements stated in the bid packet directions.

If you choose not to participate in this particular bid, please sign the Bid Proposal stating “no bid” and email it to me at [jonellmiller@vcccd.edu](mailto:jonellmiller@vcccd.edu).

It is the responsibility of the Bidder to verify that their proposal has been received by the VCCCD Purchasing Department prior to the opening date. Verification of receipt can be made through the listed Purchasing Specialist.

The following information is in answer to questions asked via email request. The verbiage remains as submitted.

The deadline for questions was Thursday, June 27, 2019 at 5:00 p.m.. No further questions will be accepted.

1. On most of the Sargent panic devices the bid called out for 36” devices, but they had a ‘J’ in their part number which indicates a 42” device. The correct designation for a 36” device is ‘F’.
  - a. Where we requested 36” bars, it should be “F”, not “J”.
2. We also noticed that the descriptions for the Sargent exit devices indicated that they are being retro fitted onto fire rated openings. However, they had the ‘49’ designation in the part number. 49 in the part number is an option that includes an indicator on the head assembly to show when the panic device has been dogged (held depressed) by a cylinder.
  - a. These retrofits **do not** dog down the panic bars; they lock in an open position without dogging down. We know about the requirements for fire rated doors.



# Ventura County Community College District

PURCHASING DEPARTMENT

---

3. There was also 'NC-E33' in the part number of those same Sargent exit devices. We cannot not find that designation anywhere in the price list or literature as a viable option code. We do not know what that nomenclature means.
  - a. The NC-E33 designation is brand new. It indicates that the thumb turn need only turn 90 degrees instead of the older version which needs to turn 180 degrees before changing the indicator from "open" to "locked".

*End of Section*