



Ventura County Community College District

PURCHASING DEPARTMENT

DATE: July 29, 2019
TO: All Bidders
FROM: Jo Nell Miller, Purchasing Specialist
SUBJECT: Addendum 1 – Bid 589 Moorpark Stadium Road Water Line Replacement

This addendum is hereby made part of the Contract Documents to the same extent as though it was originally included therein and takes precedence over the original documents. The outdated pages must be replaced with any updated and/or changed pages when submitting your bid. Acknowledge receipt of all addenda on the Bid Form.

The bid opening remains on **Thursday, August 15, 2019**. Bids must be received no later than **3:00 p.m.** at 761 E Daily Drive, Suite 200, Camarillo, CA 93010. Properly mark the outside of the exterior envelope on your submitted bid with the Bid Number and Name according to the requirements stated in the bid packet directions.

If you choose not to participate in this particular bid, please sign the Bid Proposal stating “no bid” and email or fax it back to me at 805-652-7700.

It is the responsibility of the Bidder to verify that their proposal has been received by the VCCCD Purchasing Department prior to the opening date. Verification of receipt can be made through the listed Purchasing Specialist.

The following information is in answer to questions asked at the job walk and via email request.

- See revised plan sheets 2 & 3.
- It is the Contractor's responsibility to maintain temporary water service for both the domestic water and irrigation water during the course of construction.
- Per specification section 33 10 00 Water Utilities 3.04. E. All metal fittings are to be coated and wrapped in plastic.
- The existing AC pavement that was in place during the job walk will remain for the waterline replacement project.

The deadline for questions is Monday, August 5, 2019 at 5:00 p.m. After that time, no further questions will be accepted.

End of Section