



Ventura County Community College District

PURCHASING DEPARTMENT

DATE: August 16, 2019
TO: All Bidders
FROM: Jo Nell Miller, Purchasing Specialist
SUBJECT: Addendum 1 – Bid 591 Moorpark College Lion Habitat

*This addendum is hereby made part of the Contract Documents to the same extent as though it was originally included therein and takes precedence over the original documents. The outdated pages must be replaced with any updated and/or changed pages when submitting your bid. **Acknowledge receipt of all addenda on the Bid Form.***

The bid opening remains on **Thursday August 29, 2019**. Bids must be received no later than **3:00 p.m.** at 761 E Daily Drive, Suite 200, Camarillo, CA 93010. Properly mark the outside of the exterior envelope on your submitted bid with the Bid Number and Name according to the requirements stated in the bid packet directions.

Verification of receipt of the proposal is the responsibility of the Bidder. Contact the listed Purchasing Specialist of the VCCCD Purchasing Department prior to the opening date for confirmation of receipt.

The deadline for questions is Friday, August 23, 2019. After this time, no further questions may be accepted.

Attached is the Architect's cover sheet, correcting the Bid number from Bid 585 to Bid 591. Below is the Electrical Engineer's clarification on the cables.

- The three Cat6A cables from the light pole with the cameras to the Admin Building (reptile building) should run from the camera to the IDF in the reptile building via the existing conduit system for low voltage. This cable is a wet location outdoor rated cable.

Please be sure to acknowledge receipt of Addendum 1 on your bid proposal.

End of Section



Ventura County Community College District
MOORPARK COLLEGE EATM LION ENCLOSURE - BID NO. 591

ADDENDUM # 1

August 16, 2019

The following changes, clarifications or additions and deletions are hereby made to the contract documents. All other contract requirements remain unchanged. Bidders shall acknowledge receipt of this Addendum in the Bid Form.

SPECIFICATIONS

Cover Page Replace Cover Page - Bid No. has been updated to Bid No. 591

END OF ADDENDUM

AMADOR WHITTLE ARCHITECTS, INC.

William J. Amador, AIA
Architect C20348

TECHNICAL SPECIFICATIONS

FOR

**MOORPARK COLLEGE EATM LION ENCLOSURE
VENTURA COUNTY COMMUNITY COLLEGE DISTRICT
BID No. 591**

FOR

**MOORPARK COLLEGE
7075 CAMPUS ROAD
MOORPARK, CA 93021**

**William J Amador AIA, ARCHITECT
AMADOR WHITTLE ARCHITECTS, INC**