



Ventura County Community College District

PURCHASING DEPARTMENT

DATE: August 28, 2020
TO: All Bidders
FROM: Jo Nell, Purchasing Specialist
SUBJECT: Addendum 1 – Bid 610 Fire Technology Apparatus Building
Phase II Parking Lot and Site Utilities.

This addendum is hereby made part of the Contract Documents to the same extent as though it was originally included therein and takes precedence over the original documents. The outdated pages must be replaced with any updated and/or changed pages when submitting your bid. Acknowledge receipt of all addenda on the Bid Form.

The bid opening remains on **Wednesday, September 09, 2020**. Bids must be received no later than **3:00 p.m.** at 761 E Daily Drive, Suite 200, Camarillo, CA 93010. Properly mark the outside of the exterior envelope on your submitted bid with the Bid Number and Name according to the requirements stated in the bid packet directions.

If you choose not to participate in this particular bid, please sign the Bid Proposal stating “no bid” and email or fax it back to me at 805-652-7700.

It is the responsibility of the Bidder to verify that their proposal has been received by the VCCCD Purchasing Department prior to the opening date. Verification of receipt can be made through the listed Purchasing Specialist.

The following information is in answer to questions that were asked at the job walk and via email request. The deadline for questions is Wednesday, September 02, 2020 by 3:00 p.m. No further questions will be accepted after that time.

1Q – I am currently contacting suppliers and have had a little trouble finding the type of Asphalt and Base you would specifically like to have for the job, whether it be Greenbook or something different. If you could let me know those types for the AC and AB at your quickest convenience, that would be extremely helpful.

1A – Asphalt – PG 64-10. Base shall be Class II aggregate base (Caltrans stds)

End of Section