



Ventura County Community College District

PURCHASING DEPARTMENT

DATE: May 3rd, 2022
TO: All Bidders
FROM: Spencer Herson, Purchasing Specialist
SUBJECT: Addendum 1 – Bid 634-CUPCCAA, Oxnard College Arts and Design Fire Alarms

This addendum is hereby made part of the Contract Documents to the same extent as though it was originally included therein and takes precedence over the original documents. The outdated pages must be replaced with any updated and/or changed pages when submitting your bid. Acknowledge receipt of all addenda on the Bid Form.

The bid opening remains on **Monday, May 9th, 2022**. Bids must be received no later than **3:00 p.m.** at 761 E Daily Drive, Suite 200, Camarillo, CA 93010. Properly mark the outside of the exterior envelope on your submitted bid with the Bid Number and Name according to the requirements stated in the bid packet directions.

If you choose not to participate in this particular bid, please sign the Bid Proposal stating “no bid” and email or fax it back to me at 805-652-7700.

It is the responsibility of the Bidder to verify that their proposal has been received by the VCCCD Purchasing Department prior to the opening date. Verification of receipt can be made through the listed Purchasing Specialist.

The following information is in answer to questions that were asked at the job walk and via email request. The deadline for questions was Monday, May 2nd, 2022. No further questions will be accepted.

1Q – Will we be using the existing outlet boxes in the classrooms?

1A – Yes.

2Q – What is the distance between the pull boxes for the conduit run?

2A - The total distance of the run is roughly a quarter mile with existing pull boxes approximately 150-300 feet apart.

3Q – Is there a conduit run between all buildings?

3A – Yes there is.

End of Section