



# Ventura County Community College District

PURCHASING DEPARTMENT

DATE: September 14<sup>th</sup>, 2022  
TO: All Bidders  
FROM: Spencer Herson, Purchasing Specialist  
SUBJECT: Addendum 1 – Bid 637, Oxnard College Arts and Design Fire Alarms

*This addendum is hereby made part of the Contract Documents to the same extent as though it was originally included therein and takes precedence over the original documents. The outdated pages must be replaced with any updated and/or changed pages when submitting your bid. **Acknowledge receipt of all addenda on the Bid Form.***

The bid opening remains on **Tuesday, September 20<sup>th</sup>, 2022**. Bids must be received no later than **3:00 p.m.** at 761 E Daily Drive, Suite 200, Camarillo, CA 93010. Properly mark the outside of the exterior envelope on your submitted bid with the Bid Number and Name according to the requirements stated in the bid packet directions.

If you choose not to participate in this particular bid, please sign the Bid Proposal stating “no bid” and email or fax it back to me at 805-652-7700.

It is the responsibility of the Bidder to verify that their proposal has been received by the VCCCD Purchasing Department prior to the opening date. Verification of receipt can be made through the listed Purchasing Specialist.

The following information is in answer to questions that were asked at the job walk and via email request. The deadline for questions was Monday, September 12<sup>th</sup>, 2022. No further questions will be accepted.

**1Q** – Is there a way to interconnect everything?

**1A** – Yes, everything can be interconnected underground.

**2Q** – Where is the fiber going back to?

**2A** – There will be a four connector cable that runs from the Arts and Design panel to a panel in the admin building. This cable should have no splices underground but none at all is preferable. There is existing underground conduit for the awarded contractor to use.

**3Q** – All the bathrooms are T-barred?

**3A** – Yes. Both bathrooms and classrooms are T-bar.

**4Q** – Can you please provide forms 260 Bid Security and 240 Statement of Bidders Qualifications?

**4A** – Yes. These will be attached as a part of this addendum.

*End of Section*



# Ventura County Community College District

PURCHASING DEPARTMENT

---