



# Ventura County Community College District

PURCHASING DEPARTMENT

DATE: 06/14/2024  
TO: All Bidders  
FROM: David Cienfuegos, Purchasing Specialist  
SUBJECT: Addendum 1 – Bid 676 Moorpark College Parking Lot Repair

*This addendum is hereby made part of the Contract Documents to the same extent as though it was originally included therein and takes precedence over the original documents. The outdated pages must be replaced with any updated and/or changed pages when submitting your bid. **Acknowledge receipt of all addenda on the Bid Form.***

The bid opening remains on **Tuesday, June 18th, 2024**. Bids must be received no later than **3:00 p.m.** at 761 E Daily Drive, Suite 200, Camarillo, CA 93010. Properly mark the outside of the exterior envelope on your submitted bid with the Bid Number and Name according to the requirements stated in the bid packet directions.

If you choose not to participate in this particular bid, please sign the Bid Proposal stating “no bid” and email or fax it back to me at 805-652-7700.

It is the responsibility of the Bidder to verify that their proposal has been received by the VCCCD Purchasing Department prior to the opening date. Verification of receipt can be made through the listed Purchasing Specialist.

**Attached to this addendum please find updated tech specifications, Exhibit A.**

The following information is in answer to questions that were asked at the job walk and via email request. The deadline for questions was Monday June 10, 2024. No further questions will be accepted.

1. What is the timeframe of the job?
  - a. 30 Days, see Special Conditions 00800 1.01 et al.
2. What is the date of the Notice to Proceed?
  - a. Notice to Proceed will be provided to the awarded bidder after the July 2024 Board of Trustees Meeting.
3. May recycled materials be used?
  - a. May use recycled materials in aggregate base (e.g. PMB, CMB per Green Book) under asphalt concrete course and up to 15% RAP asphalt concrete.
4. Will contractors need to pull the fire hydrants?



# Ventura County Community College District

## PURCHASING DEPARTMENT

---

- a. Permits for use of water from fire hydrants must be pulled by the Contractor. See Special Conditions 00800 1.12 et al.
  
5. Is the contractor to apply a seal coat?
  - a. Yes, after temporary striping and 90 day cure. Contractor is to seal coat and permanent stripe the lot.
  
6. Any known drainage issues?
  - a. None known at this time.
  
7. Is the contractor to provide temporary fencing?
  - a. Contractor is responsible for securing the job site.
  
8. Is the road leading to the zoo part of the bid?
  - a. No, please refer to the specs.
  
9. Are the utilities marked?
  - a. Shallow utilities have been marked however the contractor must pothole. See Exhibit A.
  
10. Will striping be provided to the contractor?
  - a. Contractor will need to memorialize the lot striping and keep to it when restriping the lot. Refer to Exhibit A for the elimination of 6 stalls.
  
11. Are contractors to paint curbs?
  - a. Yes, with traffic rated paint.

*End of Section*



# Lot 21 Utility Survey


Utility Survey for Asphalt Project Summer 2024

**Legend**

- Communication
- Electrical
- Gas
- Irrigation
- Storm\_Drain

**Approx. locations!**  
Pothole to verify.

----- -paint red curb



10 MPH

Light Pole  
Pole with 110V Power  
Last Pole with 110V Power

Moorpark College Moorpark College

All Buses < All Buses <

P-Lot M

Stop

No Buses Stop

Omit these 6 stalls

Provide active bus hammerhead during construction.

us Stop

Music Building (MB)