



Ventura County Community College District

PURCHASING DEPARTMENT

DATE: 12/05/24
TO: All Bidders
FROM: David Cienfuegos, Purchasing Specialist
SUBJECT: Addendum 1 – Bid 695 Moorpark College MA, GM, & LM Building Sliding Door Replacement

This addendum is hereby made part of the Contract Documents to the same extent as though it was originally included therein and takes precedence over the original documents. The outdated pages must be replaced with any updated and/or changed pages when submitting your bid. Acknowledge receipt of all addenda on the Bid Form.

The bid opening remains on **Tuesday, December 10th, 2024**. Bids must be received no later than **3:00 p.m.** at 761 E Daily Drive, Suite 200, Camarillo, CA 93010. Properly mark the outside of the exterior envelope on your submitted bid with the Bid Number and Name according to the requirements stated in the bid packet directions.

If you choose not to participate in this particular bid, please sign the Bid Proposal stating “no bid” and email or fax it back to me at 805-652-7700.

It is the responsibility of the Bidder to verify that their proposal has been received by the VCCCD Purchasing Department prior to the opening date. Verification of receipt can be made through the listed Purchasing Specialist.

The following information is in answer to questions that were asked at the job walk and via email request. The deadline for questions was Monday, December 2nd, 2024. No further questions will be accepted.

1. Can additional information be provided for the special key switches?
 - a. Control switch shall be keyed to A126. Exterior keyed power switches shall be provided with LFIC core.
 - b. Prove wiring from controller for future connection to Campus Access Control System and extend to above interior ceiling adjacent to door.
2. What color is the finish on the doors?
 - a. All doors shall have Dark Bronze anodized finish
3. Who is responsible for the replacement of print/graphics on the doors?
 - a. Campus is responsible for the replacement of any and all graphics on the doors.
4. Are all doors to have the special key switches?



Ventura County Community College District

PURCHASING DEPARTMENT

- a. Yes, all replaced doors are to have the key switches. See item 1 above.
5. For the LM building, are all door replacements to be done on Fridays?
 - a. No, just the First-Floor doors are to be replaced on Fridays and weekends.
6. Is there any backing on the door jams for the Second-Floor sliding doors at the LM building and if so what material?
 - a. Unknown at this time. Bidders may assume there is appropriate backing at all door locations.
7. What is the engineer's estimate for this project?
 - a. Engineer's estimate is \$100,000.00

End of Section