



# Ventura County Community College District

PURCHASING DEPARTMENT

---

DATE: 01/14/25  
TO: All Bidders  
FROM: David Cienfuegos, Purchasing Specialist  
SUBJECT: Addendum 1 – Bid 700 Moorpark College Sliding Door Replacement

*This addendum is hereby made part of the Contract Documents to the same extent as though it was originally included therein and takes precedence over the original documents. The outdated pages must be replaced with any updated and/or changed pages when submitting your bid. **Acknowledge receipt of all addenda on the Bid Form.***

The bid opening remains on **Friday, January 17<sup>th</sup>, 2025**. Bids must be received no later than **3:00 p.m.** at 761 E Daily Drive, Suite 200, Camarillo, CA 93010. Properly mark the outside of the exterior envelope on your submitted bid with the Bid Number and Name according to the requirements stated in the bid packet directions.

If you choose not to participate in this particular bid, please sign the Bid Proposal stating “no bid” and email or fax it back to me at 805-652-7700.

It is the responsibility of the Bidder to verify that their proposal has been received by the VCCCD Purchasing Department prior to the opening date. Verification of receipt can be made through the listed Purchasing Specialist.

The following information is in answer to questions that were asked at the job walk and via email request. The deadline for questions was **Friday, January 10<sup>th</sup>, 2025**. No further questions will be accepted.

1. Is contractor to replace both the doors and windows above the door for each building?
  - a. Refer to elevations on A102 for Gymnasium and A103 for LM Building. Glazed transoms are to be replaced.
2. All doors for the gym are identical?
  - a. Yes, both doors to be replaced at the gym are identical.
3. Type of emergency exit?
  - a. Push open exist, see drawing.
4. What is the work time for the ground floor door at the LM Building?



# Ventura County Community College District

## PURCHASING DEPARTMENT

---

- a. Work is to completed on Fridays or weekends, please see Special Conditions Section 00800, paragraph 1.01.
5. Is the 2<sup>nd</sup> floor door for the LM building also only to be worked on weekends?
  - a. No, 2<sup>nd</sup> floor does not have any restrictions on work time currently.
6. Is the contractor to repair the surrounding ceiling and walls of the doors?
  - a. Contractor is to repair the surrounding ceilings and walls of the doors if the repair work is required to complete the installation of the doors.
7. At the Media Arts building doors, should the exterior concrete joint be resealed at both doors or just the NE door?
  - a. Clean out joins in exterior concrete paving directly in front of both doors and provide new joint sealant flush with surface.
8. What is the engineer's estimate?
  - a. Engineer's estimate for this project is \$100,000.

*End of Section*