



Ventura County Community College District

PURCHASING DEPARTMENT

DATE: 02/3/26
TO: All Bidders
FROM: David Cienfuegos, Purchasing Specialist
SUBJECT: Addendum 2 – Bid 723 Moorpark College LM HVAC Replacement

This addendum is hereby made part of the Contract Documents to the same extent as though it was originally included therein and takes precedence over the original documents. The outdated pages must be replaced with any updated and/or changed pages when submitting your bid.

Acknowledge receipt of all addenda on the Bid Form.

The bid opening remains on **Friday, February 6th, 2026**. Bids must be received no later than **3:00 p.m.** at 761 E Daily Drive, Suite 200, Camarillo, CA 93010. Properly mark the outside of the exterior envelope on your submitted bid with the Bid Number and Name according to the requirements stated in the bid packet directions.

If you choose not to participate in this particular bid, please sign the Bid Proposal stating “no bid” and email or fax it back to me at 805-652-7700.

It is the responsibility of the Bidder to verify that their proposal has been received by the VCCCD Purchasing Department prior to the opening date. Verification of receipt can be made through the listed Purchasing Specialist.

The following information is in answer to questions that were asked at the job walk and via email request but not addressed in the previous addendum. The deadline for questions was Friday, January 30th, 2026. No further questions will be accepted.

1. Per plans, sheet M5.1, note 1 state that this sheet is for Air Balance purposes only. However, there is a detail which is referenced on the sheet to install approximately 100ft of 2 new 20" flex duct for improved air flow. Please advise if this scope should be included in our bid?
 - a. Yes, include the flex duct as indicated on the plans.

End of Section